



NOTES:

1. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 4,000 P.S.I.
2. EXTERIOR FACES OF CONCRETE WALL SHALL BE PATCHED AND RUBBED WITH CLASS II FINISH.
3. COMPACT SUB-GRADE OF SPREAD FOOTINGS TO 95%.

B SEATWALL/ RAISED PLANTER DETAIL

SCALE: N.T.S.